

Home	Analyte(s)	EPA Result*	Trigger	MCL/Action Level
HW2	Arsenic	4 ug/L**	4.5 ug/L	10 ug/L
	Total Coliform	82 cfu/100 mL	0 cfu/100 mL	5%***
	Lithium	39 ug/L	31 ug/L	
HW4 (EPA Water)	None			
HW6 (EPA Water)	Arsenic	7.6 ug/L	4.5 ug/L	10/ug/L
	Fluoride	630 ug/L	620 ug/L	4,000 ug/L
	Chromium	10.8	3.1 ug/L (Cr+6)	100 ug/L
	Lithium	236 ug/L	31 ug/L	
	Sodium	83,700 ug/L	20,000 ug/L ****	
HW7 (EPA Water)	None			
HW8a (EPA Water)	Total Coliform	54 cfu/100 mL	0 cfu/100 mL	5%***
HW12	Arsenic	6 ug/L	4.5 ug/L	10 ug/L
	Methane	52,000 ug/L	28,000 ug/L	
	Lithium	36.1	31 ug/L	
HW15a	Arsenic	5.1 ug/L	4.5 ug/L	10 ug/L
	Lithium	32.3	31 ug/L	
HW16	Barium	2910 ug/L	2,900 ug/L	2,000 ug/L
	Sodium	50,200 ug/L	20,000 ug/L****	
HW22	Arsenic	7.1 ug/L	4.5 ug/L	10 ug/L
	Chromium	4.9 ug/L	3.1 ug/L (Hex form)	100 ug/L
	Lead	22.7 ug/L	15 ug/L	15 ug/L
	Manganese	635 ug/L	320 ug/L	50 ug/L *****
	Lithium	33.5 ug/L	31 ug/L	
HW32	Arsenic	10.5 ug/L	4.5 ug/L	10 ug/L
HW35	Total Coliform	34 cfu/100 mL (Fecal present)	0 cfu/100 mL	5%***
	Lead	21.2 ug/L	15 ug/L	15 ug/L
	Sodium	28,700 ug/L	20,000 ug/L****	
HW39	Barium	3530 ug/L	2,900 ug/L	2,000 ug/L
	Sodium	47,400 ug/L	20,000 ug/L****	
	Lithium	134 ug/L	31 ug/L	
HW47	Arsenic	90.7 ug/L	4.5 ug/L	10 ug/L
	Manganese	947 ug/L	320 ug/L	50 ug/L *****
	Sodium	53,600 ug/L	20,000 ug/L****	
	Lithium	115 ug/L	31 ug/L	
HW57	Arsenic	5.8 ug/L	4.5 ug/L	10 ug/L
	Iron	11,200 ug/L	11,000 ug/L	300 ug/L *****
HW60	Arsenic	9.3 ug/L	4.5 ug/L	10 ug/L
	Lithium	47.7 ug/L	31 ug/L	
	Sodium	20,300 ug/L	20,000 ug/L****	

Notes:

* - Wellhead unfiltered results that exceed triggers.

** - During week 1 the trigger may have been reported as 4 ug/L and later revised to 4.5 ug/L.

HW 2 may have been told that they would be resampled based upon this early trigger.

*** - No more than 5% samples total coliform-positive in a month for public water providers.

**** - For persons with sodium restricted diets

***** - Secondary MCL